

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 233277			
DIV. 1	WD 1	DES. BASIN	MD

APPLICANT

Lot: 36 Block: Filing: 2 Subdiv: SADDLEWOOD

LYLE A PENNER
5481 SO RICHFIELD WAY
CENTENNIAL, CO 80015-

(303) 690-2054

APPROVED WELL LOCATION

ELBERT COUNTY
NE 1/4 SE 1/4 Section 5
Township 8 S Range 64 W Sixth P.M.

DISTANCES FROM SECTION LINES

2600 Ft. from South Section Line
700 Ft. from East Section Line

UTM COORDINATES

Northing: Easting:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(l) and policy of the State Engineer under the following conditions.
- 4) The use of ground water from this well is limited to ordinary household purposes inside one (1) single family dwelling and the irrigation of not more than 7,000 square feet of home gardens and lawns, as recommended by the Division of Water Resources to the county commissioners.
- 5) Production from this well is restricted to the Upper Dawson aquifer, which corresponds to the interval between 300 feet and 595 feet below the ground surface. Plain casing shall be installed and grouted to prevent production from other zones.
- 6) The maximum pumping rate of this well shall not exceed 15 GPM.
- 7) The annual withdrawal of ground water from this well shall not exceed 1 acre-foot.
- 8) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.

NOTE: To insure a maximum productive life of this well, perforated casing should be set through the entire producing interval of the approved zone or aquifer indicated above.

JMW 5/8/01

APPROVED
JMW

Hal D. Simpson
State Engineer

DATE ISSUED **MAY 09 2001**

By *Joanna Williams*
EXPIRATION DATE **MAY 09 2003**

Receipt No. 0475121