

FORM NO.
GWS-39
11/90

SUPPLEMENTAL TEST REPORT

STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Office Use only

RECEIVED

JAN 03 2000

WATER RESOURCES
STATE ENGINEER
COC

1. WELL PERMIT NUMBER 192371

2. OWNER NAME(S) Conrad Chichos

Mailing Address 485 Sable Blvd.

City, St. Zip Aurora, Colo. 80011

Phone (303) 363-8404

3. WELL LOCATION AS DRILLED: SW 1/4 SE 1/4, Sec. 23 Twp. 6 S, Range 64 W

DISTANCES FROM SEC. LINES:

650 ft. from South Sec. line. and 1900 ft. from East Sec. line.
(north or south) (east or west)

SUBDIVISION: Sun Country Meadows LOT BLOCK FILING(UNIT)

STREET ADDRESS AT WELL LOCATION: 7515 Shenandoah Dr.

4. STATIC WATER LEVEL: 306 ft., Date Aug. 12, 1999, Time 9:00 a.m.

Measurement Method: Sonic well probe, Length of airline (if used) N/A ft.

5. PUMP: Type Submersible, Horsepower 1.5, Setting 470 feet.

Power Source 230V AC, Discharge pipe 1 in., Discharge Pressure 35 psi.

6. FLOW METER: Manufacturer Sensus, Type in line

Diameter 3/4 inches, Average pumping rate 6.5 gpm., Volume pumped during test 754 gals.

7. TEST DATA: Date of Test Aug. 12, 1999 WELL DEPTH-705 FT. --- Recovery Data ---

Time	Pumping Level (feet)	Drawdown (feet)	Pumping rate (gpm)	Pumping Pressure (psi)	(amps)	Time	Water Level (feet)
9:44	306	0			12	11:40	410
9:47	336	30	7.75	40		11:41:25	409 PUMP OFF
9:51	364	58	7.5	39		11:42	407
10:00	390	84	7	38	11.5	11:43	402
10:07	398	92	6.5	36		11:44	392
10:50	408	102	6.25	35	11.5		
10:52	409	103	6	35			
10:59	410	104	6	35			
11:31	410	104	6	35	11.5		
11:40	410	104	6	35			

8. DISINFECTION: Type HTH granules Amt. Used 1 oz.-after sample collected

9. Water Quality analysis available. ☒ Yes ☐ No SAMPLE TAKEN IN BATHROOM

10. Remarks DWC CERTIFIES 6 Gpm SUSTAINED YIELD AT 410 FT. PUMPING LEVEL AT THE TIME OF THIS TEST.

Flow rate, drawdown and pressure stabilized during this test.

Existing pump was used for this test.

11. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge.
[Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR DOMESTIC WATER CONSULTANTS, INC. Phone (303) 423-6149 Lic. No. 1081
Mailing Address 3031 W. 133rd Ave. Broomfield, Colo. 80020

Name/Title (Please type or print)
Lloyd W. Eichacker, Vice Pres.

Signature
Lloyd W. Eichacker

Date
Aug. 12, 1999