

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 259964
DIV. 8 WD 1 DES. BASIN 2 MD

APPLICANT

J G MARSHALL
43675 PRIVATE RD 39
ELIZABETH, CO 80107-

(303) 621-0166

Lot: 16B Block: Filing: 4 Subdiv: SUN COUNTRY MEADOWS

APPROVED WELL LOCATION
ELBERT COUNTY
SE 1/4 NW 1/4 Section 25
Township 6 S Range 64 W Sixth P.M.

DISTANCES FROM SECTION LINES
2950 Ft. from South Section Line
1500 Ft. from West Section Line

UTM COORDINATES (NAD83)
Easting: Northing:

PERMIT TO CONSTRUCT A WELL

CONDITIONS OF APPROVAL


- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-105.
- 4) Water from this well may be used for domestic purposes inside 1 single family dwelling(s), and the watering of the owner's own large non-commercial domestic animals.
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The annual withdrawal of ground water from this well shall not exceed 0.5 acre-feet (162,925 gallons).
- 7) The irrigated area shall not exceed 4,500 square feet of lawn and garden.
- 8) Production is limited to the Denver aquifer. Plain casing must be installed and grouted from ground surface to a minimum depth of 325 feet to prevent diversion of water from other zones. The total depth of this well shall not exceed 1140 feet, which is the estimated base of the Denver aquifer.
- 9) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division of Water Resources upon request.
- 10) This well must be constructed within 300 feet of the location specified on this permit within lot 16B, filing 4 of the Sun Country Meadows Subdivision, Elbert County.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.


NOTE: To ensure a maximum productive life of this well, perforated casing should be set through the entire producing interval of the approved zone or aquifer indicated above.

NOTICE: This permit has been approved with a change to the permit application form from that applied for by the applicant. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)

APPROVED
SMJ



State Engineer



By

Receipt No. 0531182

DATE ISSUED 10-25-2004

EXPIRATION DATE 10-25-2006