



ORIGINAL PERMIT APPLICANT(S)

POKOJSKI JOHN & KELLY

APPROVED WELL LOCATION

Water Division: 1 Water District: 1
 Designated Basin: N/A
 Management District: N/A
 County: ELBERT
 Parcel Name: FOXWOOD RANCHES
 Lot: 4 Block: Filing:
 Physical Address: 7485 PATRICK TRAIL ELIZABETH, CO
 80107

SE 1/4 NE 1/4 Section 2 Township 6.0 S Range 64.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: 541574.9 Northing: 4378925.3

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 35 acre(s) described as Lot 4, Foxwood Ranches division of land, Elbert County, more particularly described in attached Exhibit A.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the watering of poultry, domestic animals and livestock on a farm or ranch and the irrigation of not more than one (1) acre of home gardens and lawns.
- 5) Production from this well is restricted to the Denver aquifer, which corresponds to the interval between 140 feet and 1000 feet below the ground surface. Plain casing shall be installed and grouted to prevent production from other zones.
- 6) The maximum pumping rate of this well shall not exceed 15 GPM.
- 7) The annual withdrawal of ground water from this well shall not exceed 2.9 acre-feet.
- 8) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 9) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTE: To insure a maximum productive life of this well, perforated casing should be set through the entire producing interval of the approved zone or aquifer indicated above.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.

Date Issued: 9/1/2000

Expiration Date: 9/1/2002

 Issued By

PERMIT HISTORY

- 08-16-2019 CHANGE IN OWNER NAME/MAILING ADDRESS. CHANGED TO DALE R RICE
- 08-16-2019 CHANGE IN OWNER NAME/MAILING ADDRESS. CHANGED TO BRENDA K RICE
- 06-11-2001 CHANGE IN OWNER NAME/MAILING ADDRESS